



BXUV.G563 Fire Resistance Ratings - ANSI/UL 263

[Page Bottom](#)

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Listed or Classified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered as Classified, Listed, or Recognized.

Fire Resistance Ratings - ANSI/UL 263


[See General Information for Fire Resistance Ratings - ANSI/UL 263](#)

Design No. G563

April 12, 2010

Unrestrained Assembly Rating — 1 or 2 Hr. (See Item 2)

Load Restricted for Canadian Applications — See Guide [BXUV7](#)



1. **Steel Deck** — Min 9/16 in. deep, 22 MSG galv corrugated fluted steel deck. Attached to each joist with #10 3/4 in. long screws at each side joint and no more than 10 in. OC between sides.

2. **Floor Topping Mixture*** — Compressive strength to be 3500 psi min. For a 1 hour rating, when used with Acousti-Mat CSD, minimum thickness of 1-1/2 in. as measured from the top of the mat. For a 2 hour rating, minimum thickness to be 1 in. as measured from the top plane of the deck. Refer to manufacturer's instructions accompanying the material for specific mix design. An acrylic provided by the floor-topping manufacturer shall be applied to the steel deck prior to the installation of the floor topping mixture at a maximum application rate of 300 ft²/gallon.

MAXXON CORP — Types D-C, L-R, C-T, RFU and Ortecrete.

RAPID FLOOR SYSTEMS — Types RFU, Ortecrete

2A. **Floor Mat Materials*** — (Optional) - Not Shown - Min 0.25 in. to max 0.8 in. thick floor mat material loose laid over the crests of the steel deck. Flutes of the steel deck to be filled with Floor Topping Mixture* prior to the application of the Floor Mat Materials*.

MAXXON CORP — Acousti-Mat II, Acousti-Mat 3, Enkasonic 9110

Alternate Floor Mat Materials* - (Optional) - Not Shown — Nom 0.2 in. thick floor mat material loose laid over the crests of the steel deck. Flutes of the steel deck to be filled with Floor Topping Mixture* prior to the application of the Floor Mat Materials*.

MAXXON CORP — Type Acousti-Mat LP-R

Alternate Floor Mat Materials* - (Optional) - Not Shown — For a 1 hour rating only, nom 0.8 in. thick floor mat material loose laid over the crests of the steel deck. Minimum 1-1/2 in. thick floor topping mixture applied over the ffoot mats.

MAXXON CORP — Type Acousti-Mat CSD

3. Structural Steel Members* — JoistRite channel-shaped joists, min 9-1/4 in. deep with min 2 in. wide flanges and 3/4 in. long stiffening flanges. The web of each joist is provided with 3/4 in. deep lip-reinforced trapezoidal cutouts as shown in the illustration. JoistRite rim track, min 9-3/8 in. deep with min 1-1/2 in. top flange and min 2-5/16 in. bottom flange. The joists and rim tracks are fabricated from min 16 MSG galv steel. Joists spaced max 24 in. OC. Floor joists attached to rim track using channel-shaped steel web stiffeners. At rim track splices bearing on supports, rim tracks are connected using an overlapping section of a 12 in. long splice plate, with four 3/4 in. long self-drilling #10 screws to each rim piece.

MARINO\WARE A DIV OF WARE INDUSTRIES

INC — Type JR JoistRite floor joists, Type JT JoistRite rim track

4. Blocking & Bridging — Installed before construction loads are applied. The blocking consists of JoistRite solid blocking placed between each joist. Blocking attached to the top and bottom joist flanges with one #10 3/4 in. long self-drilling screw at each end tab of blocking. Blocking is fabricated from min 18 MSG galv steel, min 1-15/16 in. flanges, having the same depth as the joists. In addition, bridging consists of 1/2 in. by 1-1/2 in. cold-rolled channel, min No. 16 GA, attached to the bottom flanges of the joists and blocking. Cold-rolled channel attached to each blocking bottom flange with four #10 3/4 in. long self-drilling screws and to joist bottom flange with two screws.

4A. Web Stiffeners — Not shown — JoistRite web stiffeners, min 3-5/8 in. wide with min 9/16 in. flange and min 1-1/4 in. flange, having the same depth as the joists. Fabricated from min 16 MSG galv steel. Secured to each joist and track with #10 3/4 in. long self-drilling screws.

5. Resilient Channels — 1/2 in. deep, formed of min 26 MSG galv steel, spaced 12 in. OC perpendicular to joists. Channel splices overlapped 6 in. beneath steel joists. Channels secured to each joist with one #10 3/4 in. long self-drilling screw. Channels oriented opposite at wallboard butt joints (spaced 6 in. OC) as shown in the above illustration.

6. Gypsum Board* — Nom 5/8 in. thick, 48 in. wide gypsum panels installed with long dimension perpendicular to resilient channels. Side joints centered between joists. Gypsum panels secured with 1 in. long Type S bugle-head screws spaced 8 in. OC in both the field and the perimeter, and 1 in. from side edges of the board.

NATIONAL GYPSUM CO — Type FSW-C

7. Batts and Blankets* — Glass fiber insulation, min 3-1/2 in. thick, bearing the UL Classification Marking for Surface Burning Characteristics and/or Fire Resistance. Insulation fitted in the concealed space, draped over the resilient channel/gypsum panel ceiling membrane. See **Batts and Blankets** (BKNV or BZJZ) Categories for names of Classified companies.

8 Joint System — Not shown — Vinyl, dry or premixed joint compound, applied in two coats to joints and screw heads; paper tape, 2 in. wide, embedded in first layer of compound over all joints.

*Bearing the UL Classification Mark

Last Updated on 2010-04-12

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2010 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online

5/13/2010

BXUV.G563 - Fire Resistance Ratings - ...

Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

