



BW-S-0024 1 HR. BOTTOM WALL STATIC JOINT

NOTES:

- 1.) SINGLE LAYER OF 5/8" TYPE X DRYWALL FOR 1 HOUR AND 2 LAYERS FOR 2 HOURS.
- 2.) ALWAYS CHECK UL FIRE RESISTANCE DIRECTORY FOR COMPLETE DESIGN REQUIREMENTS.
- 3.) ** IF THE IBC REQUIRES UL-2079 5TH EDITION, ADDITIONAL FILL MATERIAL MAY BE NEEDED IN THE DEFLECTION JOINT.