



(D)
 FG .5 (1/2" JOINT PROTECTION)
 FG1 (1" JOINT PROTECTION)
 FG1.5 (1-1/2" JOINT PROTECTION)

HW-D-0551 CENTERED DIRECTLY UNDER BEAM

- NOTES:
- 1.) SINGLE LAYER OF 5/8" TYPE X DRYWALL FOR 1 HOUR AND 2 LAYERS FOR 2 HOURS.
 - 2.) ALWAYS CHECK UL FIRE RESISTANCE DIRECTORY FOR COMPLETE DESIGN REQUIREMENTS.